Electrical Safety in the Lab Examples

August 20, 2025

Sign in Here! In-Person & On Zoom



Fire Marshall Inspection

- Inspection conducted annually
- Checklist of items Fire Marshall looks for:
 - All refrigerators, freezers, microwaves, coffee pots need to be plugged directly into a room outlet.
 - No power strips in fume hoods.
 - Power strips cannot be plugged into other power strips. They must be plugged directly into a room outlet.
 - Power strips need to have overcurrent protection. Should have a reset button.
 - No corded multiplug adapters are to be used.
 - No extension cords are to be used as permanent wiring, except for approved appliance cords.
 - All electrical cords need to go under the foil of the fume hood so it would not interfere with the sash closing all the way.
 - Fire strobes must be free from obstruction.
 - Fire extinguishers must be free from obstruction.
 - Electrical panels must be free from obstruction.
 - Means of egress should not be obstructed.
 - All gas cylinders need to be secured.




Fire Marshal Inspection – 2022/2023 Findings

605.6: Open junction boxes and open wiring splices shall be prohibited. Approved covers shall be provided for all switch and outlet boxes

The electrical cords which provide power to support equipment located in Fume Hoods are not routed properly under the air foil









Fire Marshal Inspection – 2022/2023 Findings

605.4: Relocatable power taps shall be of the polarized or grounded type, equipped with overcurrent protection, and shall be listed. Relocatable power taps shall be directly connected to a permanently installed receptacle. Relocatable power taps shall not extend through walls, ceilings, floors, under doors or floor coverings, or be subject to environmental or physical damage.

Electrical power strips are not supported and are dangling by electrical cords













Fire Marshal Inspection – 2022/2023 Findings

605.4: Relocatable power taps shall be of the polarized or grounded type, equipped with overcurrent protection, and shall be listed. Relocatable power taps shall be directly connected to a permanently installed receptacle. Relocatable power taps shall not extend through walls, ceilings, floors, under doors or floor coverings, or be subject to environmental or physical damage.

An electrical power strip is located within a ventilated chamber

Sign in Here! In-Person & On Zoom









